

Hakowski, Denise

From: Hakowski, Denise
Sent: Thursday, July 24, 2014 9:30 AM
To: Ateyeh, Laurel
Cc: Barron, Thomas; Lai, Kuo-Liang
Subject: FW: Comments on Horsham WSA -- Park Creek Cu WER
Attachments: SKMBT_C554e14062414190.pdf

Hi Laurel,

These are the comments EPA sent to Tom on Horsham. I don't know if your Central Office has additional comments.

Denise

From: Hakowski, Denise
Sent: Friday, June 27, 2014 2:41 PM
To: 'Barron, Thomas'
Cc: Walker, Dana; Trulear, Brian
Subject: Comments on Horsham WSA -- Park Creek Cu WER

I have reviewed the subject WER, and I have one follow up.

Everything looks fine, but under "Characterization of the Effluent" (which is the attached pdf), the report says "effluent quality varied with each sample as expected." I don't care if it varied, we are more interested that the plant was operating normally, and I would say that as long as it is meeting its effluent limits, we are not going to find that it wasn't.

So, as a follow up, we should compare the effluent quality in the attached with the permit limits and just make sure it is in compliance.

That's it. I think that was all the PA WERs that I currently had on my desk, so other than the Wellsboro issue, let me know if I am missing anything.

Thanks,

Denise